Safety and Security Survey

Area(s)		
Topic	Observation	Additional Comments
I. Environmental Controls		
Dropped Articles		
No Spills (water, other)		
Clean Environment		
-		
No Doors propped open		
Storage areas orderly		
Fire Extinguisher available and		
Fire Extinguisher "charge" statu		
Visual inspection of sprinkler he	eads	
18" sprinkler clearance from he	ad to nearest obstruction	
NO loose or cracked ceiling tile		
Emergency valves labeled		
Wall Penetrations Sealed		
II. Electrical/Equipment		
Condition of switches		
Condition of receptacles		
Proper extension cord use		
NO clutter		
Faulty carts, chairs, etc.		
Med carts secure and locked		
Directional signs		
Automatic doors operational		
Protective equipment available		
Adequate lighting		
Exit Lighting Operational		
III Alend/Alenner		
III. Alert/Alarms		
Pull Boxes unobstructed		
Warning signage clear		
MSDS available		
SMDA available		
Infection control available		
Alarm enunciator panels operati		
East wing fire main pressure 50		
West wing fire main pressure (5	0 psi min	
IV. Life Safety Measures		
Egress routes clear		
No corridor obstructions		
Access to Emergency Services		
Alternate public access identifie	d	

1. Additional Comments			
URVEY Conducted on		by:	
	(date)	~ J ·	(Security Officer)
eviewed by:		date:	
Director; Plant Op	erations	uatc	

Revised 4/15/99